



- STRUCTURAL SHEATHING BOARD
- FRAMING MEMBER
- 3/4" CEMENT PLASTER
- TYPAR HOUSEWRAP
- LAPPED OVER BUTYL TAPE
- STRUCTURALATH TWIN TRAC 2.5
ATTACH PER DESIGN MANUAL
- 12 MIL (min) DFT DRYLOK EXTREME
- 1/2" SCREW - 2' O/C THROUGH BUTYL
- 1/8" GAP
- STRUCTURALATH TWIN TRAC 2.5
LAP 6" (min) OVER CEMENT/BLOCK
- 2 ROWS OF STUB NAILS - TOP
AND BOTTOM - 12" O/C HORIZONTAL SPACING
STAGGER (OFFSET) TOP AND BOTTOM FASTENERS
- 3/4" to 5/8" TAPER ALLOWED
OVER 6' VERTICAL SECTION

4" WIDE
TYPAR BUTYL
TAPE. HAND
ROLLED IN
PLACE

3"
1"

SCS 04_03 MIDWALL FRAME TO CONCRETE
OR CMU (BLOCK) SMOOTH WALL FACE TRANSITION

Note:
Details to be used in conjunction with all
applicable provisions contained in the
Sealed Cladding System Design Manual.

Sealed Cladding System

07/01/2020

SCS 04_03